

SECTION 10 44 00

FIRE EXTINGUISHERS, CABINETS AND ACCESSORIES

PART 1: GENERAL

1.01 WORK INCLUDED

- A. Fire Extinguishers
- B. Cabinets
- C. Accessories

1.02 REFERENCES

- A. NFPA 10 - Portable Fire Extinguishers
- B. ADA Accessibility Guidelines
- C. UBC Standard 7-5 (ASTM E-814-83) - Fire-rated cabinet option for combustible and non-combustible walls

1.03 QUALITY ASSURANCE

- A. Conform to NFPA 10 requirements for portable fire extinguishers.
- B. Provide fire extinguishers, cabinets, and accessories by single manufacturer.

1.04 SUBMITTALS

- A. Submit product data in compliance with Section 01300 - SUBMITTALS.

PART 2: PRODUCTS

2.01 ACCEPTABLE MANUFACTURERS

- A. Where shown on the drawings, provide fire extinguishers, cabinets, accessories manufactured by Larsen's Manufacturing Co., 7421 Commerce Lane N.E., Minneapolis, MN 55432, (763) 571-1181 or (800)527-7367.

2.02 FIRE EXTINGUISHERS

- A. Dry Chemical Type: Larsen's MP or DC Series

2.03 FIRE EXTINGUISHER CABINETS

- A. Where indicated on drawings, provide Larsen's Cameo Series, model number AL C2409-6R with acrylic door. Door and trim to be fabricated from aluminum.
- B. Provide cabinets with fire-rated option, if applicable.

2.04 ACCESSORIES

- A. Extinguisher Brackets

PART 3: EXECUTION

3.01 INSPECTION

- A. Verify that rough openings for cabinets are correctly sized and located.

3.02 INSTALLATION

- A. Install the items of this Section in strict accordance with the original design, approved shop drawings, and requirements of agencies having jurisdiction, as approved by the Architect, anchoring all components firmly into position.

END OF SECTION